



Standard for NFPA 13D Fire Sprinkler Systems



SCOPE

This standard covers the permitting, installation, inspection, testing and maintenance of NFPA 13D residential fire sprinkler systems in the City of Marysville as administered by the city fire marshal (hereinafter referred to as the AHJ). The most current version of NFPA standards shall govern these installations.

Fire sprinkler systems shall meet the requirements of these codes and standards, unless specifically amended or noted otherwise, and as approved by the AHJ:

- A. NFPA 13D sprinkler systems installation standards.
- B. NFPA 25 fire protection systems maintenance standard.
- C. The International Fire Code (IFC) as amended by the city and state.
- D. The Marysville Municipal Code (MMC) [Chapter 9.04 FIRE CODE](#).

PERMITS

A fire permit from the city's Building Department is required for all sprinkler installation and modification work. The application for a fire construction permit is available [online](#). Approved plans and permit inspection cards shall be available onsite for the permitted work. A permit is only valid for the contractor and work designated by the permit.

EMERGENCY REPAIR WORK

A permit is required for repairs. Emergency repairs may begin without a permit provided the system configuration is not altered and a permit application is submitted the next working business day. A fire inspection is required for final approval of all repair work.

CONTRACTOR LICENSING

Contractors must be WA licensed for the type of work performed. (U = Underground; Level 1 = 13D; Level 2 = 13R&13D; Level 3 = 13, 13R, 13D & Underground). Proof of licensing shall be available onsite for all workers.

DESIGN REQUIREMENTS

- A. System designer qualifications shall comply with Chapter 212-80 WAC, Chapter 18.160 RCW, and Chapter 18.270 RCW as administered by the WSP (<http://www.wsp.wa.gov/fire-sprinklers/>).
- B. All plans and calculations shall be stamped with a valid Washington State certificate seal identifying the appropriate level of competency.
- C. Submittals will be sent out for engineering review at the applicant's expense.
- D. Systems shall be installed as NFPA 13D Multipurpose Piping Sprinkler looped systems, and with a minimum of 4 interconnections to domestic appliances.
- E. A single control valve shall be arranged to shut off both the domestic system and the sprinkler system. Sprinkler Control Valve signage shall be provided.
- F. A drain shall be installed on the system side of the domestic shut-off.
- G. A minimum of one head shall be installed on the garage side of the door leading into the residence from an attached garage.



Standard for NFPA 13D Fire Sprinkler Systems



UNDERGROUND PIPING

- A. All underground sprinkler supply piping shall be included on civil drawings and shall be approved by the water supplier and the Marysville Fire District (MFD).
- B. Per City of Marysville Water Dept.: *"Install the water service per our Standard Plan 2-090-001 Full ¾" x 1" Meter Service. Under this plan a 1" tap is made at the water main and 1" piping is run to the 1" meter setter. If in the end a ¾" water meter will suffice then all that is required is to install two reducer bushings with the ¾" water meter. A single service tap should be used where sprinklers are required, not a double service installation."*

WATER SUPPLIES & ACCEPTANCE TESTING

Water supplies for residential sprinkler systems shall be from the public main unless a private water supply main is approved by the AHJ. Available flow information shall be obtained from the Marysville Water Utilities Division. Hydraulic calculations are required for all installations, and for alterations involving more than five sprinklers. Sprinkler flow tests are required to prove the water supply adequacy (bucket tests).

INSPECTIONS

Fire inspections are required from the Marysville Fire District (MFD) for permitted work. Call the MFD Inspection Request Hotline 24/7 at (360) 363-8525 to request all fire inspections. Approved plans and permit inspection cards must be available on site during inspections. The installing contractor shall pretest all systems prior to requesting an inspection. If fire code violations are noted, correction will be required for approval.

MAINTENANCE

The installer shall provide to the owner/occupant instructions on inspecting, testing, and maintaining the system. The sprinkler system shall be inspected and tested periodically to make sure the system is in good working condition. Sprinkler systems shall be maintained and tested per the procedures in NFPA 25 and manufacturers' instructions.