



# Marysville Fire District

Joshua Farnes, Fleet & Facilities Supervisor  
1094 Cedar Ave.  
Marysville, WA 98270  
www.marysvillefiredistrict.org

425-754-5233  
FAX 360 658-5932  
Headquarters 360 363-8500  
jfarnes@mfdrrfa.org

## **Addendum #1**

Station #63 Generator Replacement  
Bid Closing 3:00PM January 27, 2023

Addendum Date: January 12, 2023

### **Notice to Bidder.**

The Bid Documents for the above-referenced Project are modified as set forth in this Addendum. The original Bid Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the Bid Documents.

The following are clarifications and questions to the bid specifications.

1. Fuel type shall be Liquid Propane Gas Vapor regulated at the supply tank.
2. Bid opening shall take place at:  
Marysville Fire District  
Administration Building  
1094 Cedar Ave.  
Marysville, WA 98270  
January 27<sup>th</sup> at 3:15pm
3. Generator engine shall be liquid cooled. Air cooled and/or residential application generators are not desired.
4. Project is estimated to be less than \$55,000.
5. It is desired that this project shall be completed prior to March 31, 2023. Delays beyond this date due to supply chain issues shall be included with the bidders proposal and will be evaluated for responsiveness by the Marysville Fire District.

**END OF ADDENDUM**