



Standard for Commercial Knox Boxes

1. SCOPE

This standard covers the requirements for installation of commercial Knox Boxes in the City of Marysville as administered by the district's fire marshal. Installations shall meet the requirements of these codes and standards, unless specifically amended or noted otherwise, and as approved by the AHJ:

- The International Fire Code (IFC) as amended by the city and state.
- The Marysville Municipal Code (MMC) [Fire Code Chapter 9.04](#).


2. WHERE REQUIRED

Commercial Knox Boxes are required for any building equipped with a fire alarm system and/or sprinkler system for firefighters to gain access during an emergency response.

3. KNOX BOX TYPE

Shall be recessed model KLS-3270 (as shown below) <https://www.knoxbox.com/>

Model KLS-3270 – KnoxBox 3200, Recess Mount, Hinged Door, Black



Commercial KnoxBoxes
KnoxBox® 3200
 Standard Capacity Model: KLS-3270

1. Color

Aluminum

Black

Dark Bronze

2. Mount Type

Recessed Mount

Surface Mount

3. Tamper Switch Type

None

Fire Alarm / Panel

Security Alarm

For Ordering Support

Call: 800-552-5669
 6:00 AM - 4:00 PM MST

Installation Address ?

The installation address is where this product will be installed. Do not enter the shipping address here.

Available for:
 Marysville Fire Dist - Marysville, WA

4. MOUNTING REQUIREMENT

- a. 60 inches vertically to bottom edge of box from finished floor.
- b. 12 - 24 inches horizontally to nearest edge of box, on handle side.

Example of acceptable mounting location:



5. WHERE MULTIPLE KNOX BOXES ARE REQUIRED

- a. Buildings having more than one fire alarm control panel in separate areas, depending on distance.
- b. Buildings having more than one sprinkler control valve access point. For buildings with remote risers, a separate Knox Box shall be installed at the nearest access door to each riser area.
- c. Where required as directed by the fire code official.

6. REQUIREMENTS FOR EXISTING BUILDINGS

- a. **Key box maintenance:** whenever locks accessing fire controls are re-keyed, please notify Marysville Fire District as soon as possible. A staff member will meet on site to place new key(s) in box. Call the Help Line at 360-363-8525 and leave a voicemail. You may also make a request by emailing MFInspectors@mfdrrfa.org.
- b. Key boxes that are damaged or missing shall be replaced immediately with a **3200 series Knox Box** at the expense of the building owner.
 - a. The fire marshal recommends a **recessed** Knox Box for additional security. See item #3 above.